



SA Technical Service for ABCD Corporation




Table of Contents

- Company Profile & Task Force
 - Deliverables
 - Introduction of Power Supply System
 - RAMS Introduction
 - Reliability Analysis of Station Service Loads
 - Component Reliability Behaviors
 - System Reliability Analysis
 - Conclusions

Company Profile & Task Force

Key Operations

UniteTek will corporate with System Assurance Operation Plan of ABCD Corporation to provide the following operation services:

- **System assurance plan of power supply system**

Excerpt: Target Value of Safety, Reliability, Availability, and Maintainability of power supply system, coordination, negotiation.....

- **Hazard analysis of power supply system**

Excerpt: Hazard Control, Hazard and Operability study, HAZOP, Hazard Analysis Reports, Hazard Log.....

- **Safety analysis of power supply system**

Excerpt: Data of Hazard Analyses, Quantified Risk Assessment, Safety Target.....

- **Reliability analysis of power supply system**

Excerpt: Reliability Analyses of Third Rail and 22kV/380V Transformer, Reliability Analysis Modeling, Single Line Diagram, MTTF (Mean Time To Failure).....

- **Availability analysis of power supply system**


Excerpt: Availability Analyses of Third Rail and 22kV/380V Transformer, MTBF (Mean Time Between Failure).....

- **Mmaintainability analysis of power supply system)**

Excerpt: lognormal distribution, tmedian, and Error Factor of GIS, Gas Insulated Switch, 161kV/22kV Transformer, Rectifier, Ring Main Unit, 22kV/380V Transformer, Rectifier-Transformer, Diesel emergency Generator, Breaker.....


- **FMECA of power supply system**

Excerpt: Failure Modes, Effects, and Criticality Analysis, Failure rate information.....




Deliverables

(Total 16 reports, wherein title, issuing date, and detail description are all reserved.)





Introduction of Power Supply System

- Traction Power supply



- Station Service Power supply






RAMS introduction


Safety

乘客死亡數/十億延人公里




Reliability

- $R(0) = 1$
- $R(\infty) = 0$
- monodecrease
- $0 \leq R(t) \leq 1$ for $0 \leq t < \infty$
- MTTF




Maintainability


- $M(0) = 0$
- $M(\infty) = 1$
- mono-increase
- $0 \leq M(t) \leq 1$ for $0 \leq t < \infty$
- MTTR



Availability


- $A(t) = f(R(t), M(t))$
- $A(0)=1$
- $0 \leq A(t) \leq 1$
- $A_{ss} = \text{MTTF}/(\text{MTTF} + \text{MTTR})$





Reliability Analysis of Station Service Loads

- Reliability Definition:




Electricity structure

*The probability that an **item** can perform a **required function** under given conditions for a given time interval.*



Power supply to NEL, EL or VL

• Station Service Loads



- Power Supply Logics

- 1 161kV redundancy configuration of 'h'

- 2 380V bus tie-in connection

- 3 D/G back-up power supply


161 kV SF₆ Gas Insulated Switchgear



161kV/22kV Oil Immersed Transformer




161kV/22kV Oil Immersed Transformer




Ring Main Unit (RMU)




Diesel Generator, DG



Diesel Generator, DG






Component Reliability Behaviors

$$f(t) = e^{-\frac{(\ln t / t_{\text{median}})^2}{2 (\ln EF / 1.645)^2}} / t \cdot (\ln EF / 1.645) \cdot \sqrt{2\pi}$$


$$R(t) = 1 - \int_0^t f(t) dt = \frac{1}{2} \left[1 - \operatorname{erf} \left(\frac{\ln t / t_{\text{median}}}{(\ln EF / 1.645) \cdot \sqrt{2}} \right) \right]$$

$$\text{MTTF} = \int_0^{\infty} t f(t) dt = t_{\text{median}} \cdot e^{(\ln EF / 1.645)^2 / 2}$$


Failure probability density function, $f(t)$ of Circuit Breaker




Reliability, $R(t)$ of Circuit Breaker




Failure probability density function, $f(t)$ of Diesel Generator





Reliability, $R(t)$ of Diesel Generator








System Reliability Analysis

















Reliability contribution of D/G is marginal !







Conclusions

①	#	MTTF (hr)
	NEL	38,100
	EL	49,100
	VL	50,000

② Redundancy of 161 kV 'h' configuration
13,000 hr ↗ 27,700 hr

③ Effectiveness of 380V tie-in connection
38,100 hr ↗ 49,100 hr

④ Diesel generator contribution is marginal.
49,100 hr ↗ 50,000 hr